

VOC Content Test Certificate

Wednesday October 19th, 2011

Manufacturer: Ramset New Zealand

Sample Description: Ramset HiSeal FC

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	Ramset HiSeal FC
New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3	
Architectural Sealant 250 grams per Litre as VOC content material.	92 grams per Litre as VOC content material
Specification	Ramset HiSeal FC
Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11	
Architectural Sealant 250 grams per Litre as VOC content material.	92 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV110909b