

# VOC Content Test Certificate

Wednesday October 19<sup>th</sup>, 2011

Manufacturer: Ramset New Zealand

Sample Description: Ramset HiSeal Duramax

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b>	<b>Ramset HiSeal Duramax</b>
Architectural Sealant 250 grams per Litre as VOC content material.	<b>10 grams per Litre as VOC content material</b>
<b>Specification</b>  <b>Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</b>	<b>Ramset HiSeal Duramax</b>
Architectural Sealant 250 grams per Litre as VOC content material.	<b>10 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV110909b